



NOTES:

1. EXPANSION JOINTS: 1/2 INCH THICK PRE-MOLDED NON-EXTRUDING FILLER HOMEX-300 OR APPROVED EQUAL. JOINT SEALER SHALL BE AS ONE COMPONENT, GUN-GRADE, MOISTURE CURED EPOXY OR URETHANE SUCH AS "VULCUM 45" OR EQUAL AS APPROVED BY THE ENGINEER. PLACE AT INTERFACE WITH OTHER STRUCTURES AND AS REQUIRED WITH A MAXIMUM 100 FOOT SPACING.
2. CONTRACTION JOINTS: SAW-CUT OR TOOLED GROOVE 1/4 INCH WIDE IN THE TOP ONE INCH OF WET CONCRETE WITH GROOVING TOOL OF 1/4" RADII. CLEAN AND SEAL JOINT. MATCH SPACING OF ADJOINING SIDEWALK WHERE PRESENT OR STANDARD SPACING OF 6 FEET.
3. FINISHING: METAL FLOAT THEN LIGHT BROOM. UPPER LONGITUDINAL EDGES TO BE ROUNDED AND FINISHED USING 1/4" RADIUS, 4 INCH WIDE EDGING TOOL OR AS DIRECTED. TRANSVERSE EXPANSION AND CONTRACTION JOINTS TO BE ROUNDED AND FINISHED USING 1/4" RADIUS, 2 INCH WIDE EDGING TOOL. PICTURE FRAME FINISH BETWEEN CONTRACTION JOINTS UNLESS SPECIFIED OTHERWISE BY ENGINEER OR ADJACENT SITE CONDITIONS.



BOARD OF
PARKS AND
RECREATION
COMMISSIONERS
CITY OF
KANSAS CITY, MISSOURI

4600 E. 63rd Street
Kansas City, MO 64130
Bus: (816) 513-7500
Fax: (816) 513-7605
Web: www.kcmo.org/parks

KCMO PARK'S STANDARD DETAILS

CJ
CONCRETE JOINT

DESIGNER: T. KIEFER
DATE: 10 APR 2013
ARCHIVE NO:

CJ

STANDARD DRAWING NO.